

**CITY OF TEMPE AMENDMENTS TO THE
2003 INTERNATIONAL FUEL GAS CODE
ARTICLE VII, SECTION 8-700 OF THE
TEMPE CITY CODE**

Sec. 201. GENERAL.

[§ 201.4 is hereby amended as follows:]

"*Section 201.4. Terms not defined.* Where terms are not defined through the methods authorized by this chapter, such terms shall have ordinarily accepted meanings such as the context implies. Webster's Third New International Dictionary of the English Language, Unabridged, shall be considered as providing ordinarily accepted meanings."

Sec. 301. GENERAL.

[§ 301.2 is hereby amended as follows:]

"*Section 301.2. Energy utilization.* Heating, ventilating and air-conditioning systems of all structures shall be designed and installed for efficient utilization of energy."

Sec. 303. APPLIANCE LOCATIONS.

[§ 303.3 is hereby amended as follows:]

"*Section 303.3. Prohibited locations.* Fuel-fired appliances shall not be located in, or obtain combustion air from, any of the following rooms or spaces:

1. Sleeping rooms.
2. Bathrooms.
3. Toilet rooms.
4. Storage closets.
5. Surgical rooms.
6. Any room operating under negative pressure unless the appliances are listed for that use."

Sec. 303. APPLIANCE LOCATIONS.

[§ 303.7 is hereby amended as follows:]

"*Section 303.7. Pit locations.* Appliances installed in pits or excavations shall not come in contact with the surrounding soil. The sides of the pit or excavation shall be held back a minimum of 12 inches (305 mm) from the appliance. Where the depth exceeds 12 inches (305 mm) below adjoining grade, the walls of the pit or excavation shall be lined with concrete or masonry. Such concrete or masonry shall extend a minimum of 4 inches (102 mm) above to adjacent grade and shall have sufficient lateral load-bearing capacity to resist collapse. The appliance shall be protected from flooding in an approved manner. Liquefied petroleum (LPG) appliances shall not be installed in a pit, attic or other location that would cause a ponding or retention of gas."

Sec. 304. COMBUSTION, VENTILATION AND DILUTION AIR.

[§ 304.1 is hereby amended as follows:]

"Section 304.1. General. Air for combustion, ventilation and dilution of flue gases for gas utilization equipment installed in buildings shall be provided by application of one of the methods prescribed in Sections 304.5 through 304.9. Where the requirements of Section 304.5 are not met, outdoor air shall be introduced in accordance with one of the methods prescribed in Sections 304.6 through 304.9. For LPG appliances, any duct serving the lower opening shall be at the floor level and slope to the outdoors without traps or pockets. Direct-vent appliances, gas appliances of other than Category I shall be provided with combustion ventilation and dilution air in accordance with the equipment manufacturer's instructions."

Sec. 305. INSTALLATION.

[§ 305.3, exception is hereby amended as follows:]

"Exceptions:

1. Elevation of the ignition source is not required for appliances that are listed as flammable vapor resistant and for installation without elevation.
2. Direct-vent appliances that obtain all combustion air directly from the outdoors.
3. Clothes dryers installed in private garages."

Sec. 305. INSTALLATION.

[§ 305.7 is hereby amended as follows:]

"Section 305.7. Clearances from grade. Equipment and appliances installed at grade level shall be supported on a level concrete slab or other approved material extending a minimum of 3 inches (76 mm) above finished grade or shall be suspended a minimum of 6 inches (152 mm) above finished grade."

Sec. 404. PIPING SYSTEM INSTALLATION.

[§ 404.9 is hereby amended as follows:]

"Section 404.9. Minimum burial depth. Underground piping systems shall be installed a minimum depth of 12 inches (305 mm) below grade for metal, and 18 inches (457 mm) below grade for plastic piping."

Sec. 404. PIPING SYSTEM INSTALLATION.

[§ 404.9.1 is hereby repealed.]

Sec. 406. INSPECTION, TESTING AND PURGING.

[§ 406.4 is hereby amended as follows:]

"Section 406.4. Test pressure measurement. Test pressure shall be measured with a manometer or with a pressure-measuring device designed and calibrated to read, record, or indicate a pressure loss caused by leakage during the pressure test period. The source of pressure shall be isolated before the pressure tests are made."

"406.4.1 **Test pressure.** The test pressure to be used shall be no less than ten (10) pounds per square inch (69 kPa) gauge pressure, or where approved by the Building Official, the piping and valves may be tested at a pressure of at least six (6) inches (152.4 mm) of mercury, measured with a manometer or slope gauge. For welded piping, and for piping carrying gas at pressures in excess of fourteen (14) inches (0.4m) water column pressure, the test pressure shall be no less than sixty (60) pounds per square inch (413 kPa). Where the test pressure exceeds 125 psig (862 kPa gauge), the test pressure shall not exceed a value that produces a hoop stress in the piping greater than 50 percent of the specified minimum yield strength of the pipe.

"406.4.2 **Test duration.** Test duration shall be not less fifteen (15) minutes or for welded pipe and piping carrying gas at pressures in excess of fourteen (14) inches (0.4m) water column pressure, the test duration shall be not less than thirty (30) minutes. The duration of the test shall not be required to exceed 24 hours.

"406.4.3 **Test Gauges.** Tests required by this Code which are performed utilizing dial gauges shall be limited to gauges having the following pressure increments or graduations.

"406.4.3.1. Required pressure tests of ten (10) pounds (69 kPa) or less shall be performed with gauges having increments of one-tenth (1/10) pound (0.69 kPa) or less.

"406.4.3.2. Required pressure tests exceeding ten (10) pounds (69 kPa) but less than one hundred (100) pounds (690 kPa) shall be performed with gauges having increments of one (1) pound (7 kPa) or less.

"406.4.3.3. Required pressure tests exceeding one hundred (100) pounds (690 kPa) shall be performed with gauges having increments 2 psi (14 kPa) or less.

"406.4.3.4 Pressure tests required by this code, which are performed utilizing dial gauges, shall be limited to a gauge having a maximum gauge rating not exceeding twice the applied test pressure."